D DEKR

Translation

1. Supplement to the EC-Type Examination Certificate

- (2) Equipment and protective systems intended for use in potentially explosive atmospheres Directive 94/9/EC Supplement accordant with Annex III number 6
- (3) No. of EC-Type Examination Certificate: BVS 14 ATEX E 122 X

(4) Equipment: Ex-luminaire type ASL57LED-Ex

(5) Manufacturer: F. H. Papenmeier GmbH & Co. KG

(6) Address: Talweg 2, 58239 Schwerte, Germany

- (7) The design and construction of this equipment and any acceptable variation/thereto are specified in the appendix to this supplement.
- (8) The certification body of DEKRA EXAM GmbH, notified body no 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive. The examination and test results are recorded in the test and assessment report BVS PP 14.2172/EG.
- (9) The Essential Health and Safety Requirements are assured by compliance with

EN 60079-0:2012 + A11:2013 | General requirements | EN 60079-1:2007 | Flameproof enclosure "d" | EN 60079-7:2007 | Increased safety "e" |

EN 60079-31:2009 Protection by enclosure "t"

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the appendix to this certificate.
- (11) This supplement to the EC-Type/Examination/Certificate/relates only to the design, examination/and tests of the specified equipment in accordance to Directive 94/9/EC.

 Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment shall include the following:

	II 2G	Ex d IIC T6 Gb	///or////	(without terminal compartment)
$\langle x3 \rangle$	II 2G	Ex d e IIC T6 Gb	//and///	(with terminal compartment)
	II 2D	Ex tb IIIC T80°C Db	HHHH	//(all types)////////////////////////////////////

DEKRA EXAM GmbH Bochum, dated 2015-08-07

Signed:	Signed: ////////////////////////////////////			
Certification body	Special services unit			



DEKRA RA DE DEKRA

KRA D

DEKRA

DEKRA D

- (13) Appendix to
- (14) 1. Supplement to the EC-Type Examination Certificate BVS 14 ATEX E 122 X
- (15) 15.1 Subject and type


Ex-luminaire type ASL57LED-Ex

15.2 Description

The Ex-luminaire type ASL57LED-Ex is designed in type of protection Flameproof Enclosure 'd', optional with terminal compartment in type of protection Increased Safety 'e', for use in areas endangered by gas atmosphere and in type of protection Protection by Enclosure 't' for use in areas endangered by dust atmosphere.

The lamp consists of a tubular housing. This housing is divided in two separated compartments, one as luminaire and the other as power supply compartment. The interconnection between both rooms is realised by use of separately tested and certified cable glands.

The luminaire compartment is closed by a tight potting compound.



The connection of the lamp is done by use of the cable gland or by use of the terminal compartment if existing.

In case of direct lead-in into the power supply compartment the used cable gland is either with setting compound or with sealing ring which have been tested for usage with this luminaire. See also clause 15.3 Parameters for details.

Reasons for this supplement:

- Addition of further separately certified cable glands with sealing ring
- Addition of supply voltage 24 VAC
- Several minor changes of the construction without influence to the explosion protection.

15.3 Parameters

There are different variants of Ex-luminaires type ASL57LED-Ex which can be identified by the given marking on the type plate.

15.3.1 Electrical / Thermal parameters

U _{rated}	P _{rated}	Lamp	Connection / / /	T-class/	T _{surface} //	T _{ambient} ////////////////////////////////////
24 VAC / VDC	35 W	Cree LED	'e' compartment	T6////	T80 °C	-20 °C ≤ T _{amb} ≤ 40 °C
			Gland ///////	X//////	M//////	<i>\\}}\\</i>
		Bridgelux LED	'e' compartment	X//////	N//////	<i>\\}}\\</i>
			Gland //////	X//////	NHH	<i>\\}\\\\\</i>
110 - 230 VAC		Cree LED	'e' compartment	X//////	A//APP	<i>\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\</i>
			Gland	X ///////	VMM	
		Bridgelux LED	'e' compartment	1//////	1/4/A/A	
	7	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Gland		47/1/1/	

15.3.2 Miscellaneous parameters

Degree of protection

IP65 / IP67



DEKRA D

15.3.3 Cable gland (without setting compound)

Type Certificate Clamping range [mm]

15.3.4 Supply line (together with cable gland according to clause 15.3.3)

Туре	Cross section	Diameter [mm]	Mir	n. length [m]
Sinotherm 110 H05GG-7	3x 1.5 mm ²	8.6	1	
Sillflex UR AWG18	5x 1.0 mm ²	10.3	1	
Ölflex Heat 180 H05SS-F	3x 1.5 mm ²	8.9	1	
Ölflex Classic 110 Black	3x 1.5 mm ²	10.2	1	

(16) Test and assessment report

BVS PP 14.2172 EG as of 2015-08-07

(17) Special conditions for safe use

Fasteners with a screw quality of A2-70 minimum have to be used for the closing of the flameproof enclosures.

The lengths of the flameproof joints are in parts longer and the gaps of the flameproof joints are in parts smaller than the values of table 2 of EN 60079-1:2007. For information of the dimensions of the flameproof joints contact the manufacturer.

We confirm the correctness of the translation from the German original. In the case of arbitration only the German wording shall be valid and binding

DEKRA EXAM GmbH 44809 Bochum, 2015-08-07 BVS-Kir/Ar A 20150634

Certification body

Special/services unit



Translation

(1) EC-Type Examination Certificate

- (2) Equipment and protective systems intended for use in potentially explosive atmospheres Directive 94/9/EC
- (3) No. of EC-Type Examination Certificate: BVS 14 ATEX E 122 X

(4) Equipment: Ex-luminaire type ASL57LED-Ex

(5) Manufacturer: F.H. Papenmeier GmbH & Co. KG

(6) Address: Talweg 2, 58239 Schwerte, Germany

- (7) The design and construction of this equipment and any acceptable variation thereto are specified in the appendix to this type examination certificate.
- (8) The certification body of DEKRA EXAM GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive. The examination and test results are recorded in the Test and Assessment Report BVS PP 14.2172 EG.
- (9) The Essential Health and Safety Requirements are assured by compliance with:

EN 60079-0:2012 General requirements
EN 60079-1:2007 Flameproof enclosure "d"
EN 60079-7:2007 Increased Safety "e"
EN 60079-31:2009 Protection by Enclosure "t"

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the appendix to this certificate.
- (11) This EC-Type Examination Certificate relates only to the design examination and tests of the specified equipment in accordance to Directive 94/9/EC.

 Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment shall include the following:

Ex II 2G Ex d IIC T6 Gb
II 2G Ex d e IIC T6 Gb
II 2D Ex tb IIIC T80°C Db

or and

(w/o terminal compartment) (with terminal compartment) (all types)

DEKRA EXAM GmbH

DEKRA EXAM GmbH Bochum, dated 2014-07-30

Signed: Schumann	Signed: Dr. Wittler		
Certification body	Special services unit		

DEKRA D

- (13) Appendix to
- (14) EC-Type Examination Certificate BVS 14 ATEX E 122 X
- (15) 15.1 Subject and type

Ex-luminaire type ASL57LED-Ex

15.2 Description

The Ex-luminaire type ASL57LED-Ex is designed in type of protection Flameproof Enclosure 'd', optional with terminal compartment in type of protection Increased Safety 'e', for use in areas endangered by gas atmosphere and in type of protection Protection by Enclosure 't' for use in areas endangered by dust atmosphere.

The lamp consists of a tubular housing. This housing is divided in two separated compartments, one as luminaire and the other as power supply compartment. The interconnection between both rooms is realised by use of separately tested and certified cable glands.

The luminaire compartment is closed by a tight potting compound.

The power supply compartment is closed by a lid with a separately certified cable gland or by a lid with a cast-on terminal compartment and a separately certified line bushing.

The connection of the lamp is done by use of the cable gland or by use of the terminal compartment if existing.

In case of direct lead-in into the power supply compartment the used cable gland is with setting compound.

15.3 Parameters

There are different variants of Ex-luminaires type ASL57LED-Ex which can be identified by the given marking on the type plate.

Electrical / Thermal parameters

U_{rated}	P _{rated}	/ Lamp / / / / /	Connection ///	T-class//	T _{surface} ///	Tambient ////////////////////////////////////
24 VDC	35 W	Cree LED	/e/compartment/	16/////	/T80/%C///	-20 °C ≤ T _{amb} ≤ 40 °C
		MHHHHHH	Gland //////	X///////	N/////////	<i>MHHMMM</i>
		Bridgelux LED	/e/compartment/	\ ///////	N/////////	
			Gland //////	X///////	N/////////	<i>W////////////////////////////////////</i>
110 - 230		Cree LED	e compartment	/ ///////	V/////////////////////////////////////	<i>\}}}} \} \ </i>
VAC			Gland //////	X//////X	V////////	<i>\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\</i>
		Bridgelux LED	/e'compartment/	V//////	V////////	<i>\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\</i>
		WELLETH () () () () () ()	Gland///////	X///////	V/I/I/I/I	<i>W////////////////////////////////////</i>

Miscellaneous parameters

Degree of protection

IP 65

DEKRA S

(16) Test and Assessment Report

BVS PP 14.2172 EG as of 2014-07-30

(17) Special conditions for safe use

Fasteners with a screw quality of A2-70 minimum have to be used for the closing of the flameproof enclosures.

The lengths of the flameproof joints are in parts longer and the gaps of the flameproof joints are in parts smaller than the values of table 2 of EN 60079-1:2007. For information of the dimensions of the flameproof joints contact the manufacturer.

We confirm the correctness of the translation from the German original. In the case of arbitration only the German wording shall be valid and binding.

DEKRA EXAM GmbH 44809 Bochum, 2014-07-30 BVS-Kir/Ma A20130898

Certification body

Special services unit